

KARNATAKA POWER TRANSMISSION CORPORATION LIMITED



Office of the
Chief Engineer(Elec)
(TA&QC)
Room No 410, 4th Floor,
Kaveri Bhavan,
Bangalore - 560 009.

Fax No : 080-22217227
Phone No: 080-22100710

No: CEE(TA&QC)/ SEE(Plg)/EE(Plg)/KCO-93/17405/F-346 Date: ~~24-02-2010~~ 15.12.2010.

M/s Shree Kedarnath Sugars & Agro Products Ltd.
Kerkalmatti Village,
Badami Taluk,
Bagalkot District.

Sirs,

Sub : Regular inter connection approval for inter connecting proposed 18 MW gross, and 13 MW exportable Co-generation power of M/s. Kedarnath Sugars and Agro Products Ltd at Kerkalmatti village, Badami taluk, Bagalkot district.

Ref : 1) Your letter No.SKSAPL/Co-gen/ CEE(TA&QC)/09-10/589 dtd 06/12/2010

2) CEIG regular commissioning approval letter No:CEIG/EI-3/AEI-3/BGT-58/27468-72 dated 6/12/2010.

3) T.O. Note approved dated 14/12/2010.

Referring to your above letter it is to intimate that your request for permitting regular inter connection from 6/12/2010, of 13 MW exportable Co-generation power from your project at Kerkalmatti village, Badami taluk, Bagalkot district, which was under provisional inter connection, has been considered and in this regard I am hereby directed to communicate **Regular inter connection approval from 6/12/2010 onwards i.e. from the date of CEIG approval date** subject to currency of G.O. in force to interconnect the above installation with capacity of 18 MWs gross and 13 MWs exportable Co-generation power with KPTCL grid and in accordance with the approved drawings and standard conditions as noted below


- 1) The Metering should be at the HV side of the transformer at the switch yard of the sugar factory of M/s. Kedarnath Sugars & Agro Products Ltd.
- 2) Regular Synchronization should be done in the presence of the Executive Engineer El., RT KPTCL and the Executive Engineer El, TL&SS KPTCL of the area, Executive Engineer El., O&M Division and EE MT Division of KPTCL.
- 3) Procedure for line clear, authorized persons etc has to be discussed and finalized between Executive Engineer El. TL&SS, EE O & M Division and firms representative if necessary for regular interconnection.
- 4) Paper notification, if required for charging the line may be issued.
- 5) This letter is only for the purpose of facilitating early commissioning of the Project KPTCL does not make any commitment to purchase power nor

make any payments for sale of energy with respect to the terms of Power Purchase agreement, which will be as approved by KERC.

- 6) The field officers should ensure that the approved evacuation scheme works are completed.
- 7) The Executive Engineer El., TL&SS of the area along with Executive Engineer El., O&M Division, of concerned KPTCL has to take meter reading of meters.
- 8) All equipments installed, Bays constructed and metering shall be SCADA compatible and shall be able to integrate with KPTCL system.
- 9) In event of loss of generation due to line outages then the IPPs shall execute an undertaking stating that they will not hold KPTCL responsible for any delay and for line outages

This Regular Interconnection approval will only provide technical connectivity of the subject installations with KPTCL grid. The firm is required to comply with all the connectivity conditions stipulated in KERC Grid code

Yours faithfully,


Chief Engineer Ele, 15/12
(TA&QC)

Copy for Kind information to:

- 1) The Managing Director, HESCOM, Hubli.

Copy for information to:

- 2) The Chief Engineer Elect. , Transmission Zone, KPTCL, Bagalkot.
- 3) The Chief Engineer Elect.(P&C),KPTCL,Kaveri Bhavan Bangalore.
- 4) The Chief Engineer Elect.(SLDC),KPTCL,AR Circle, Bangalore.
- 5) The Superintending Engineer Elec., Transmission W&M Circle Bagalkot.
- 6) The Superintending Engineer Elec., RT Circle, KPTCL, Hubli.
- 7) The Superintending Engineer Electl. , (Technical), KPTCL, Kaveri Bhavan, Bangalore - 560 009.
- 8) The Project Director, PCKL, Kaveri Bhavan, Bangalore
- 9) The Executive Engineer Elect. , Major Works Division, KPTCL, Bagalkot.
- 10) The Executive Engineer Elect. , TL&SS, Division, KPTCL, Bagalkot
- 11)The Executive Assistant to Director Transmission, KPTCL with a request to place before Director Transmission.
- 12)The Ex. Engineer Elect., RT Division, KPTCL, Belgaum.
- 13)O/C to Executive Engineer Electl, Planning.